



1. DETAILS NOT SHOWN ARE TO BE SIMILAR TO THOSE SHOWN FOR "MANHOLE" AND "SEWER FLOW CHANNEL" STANDARDS.
2. DROP MANHOLE MUST BE USED WHEN DIFFERENCE BETWEEN INVERTS IS 1'-6" OR MORE. PROVIDE A TEE AT THE TOP AND 90° BEND AT THE BOTTOM AS SHOWN.
3. ALL PVC PIPE MATERIALS TO BE C900.
4. INSIDE DROPS MAY BE APPROVED ONLY FOR EXISTING MANHOLES, AFTER DESIGN SUBMITTAL TO THE CITY'S PROJECT MANAGER.
5. STANDARD PRECAST DROP MANHOLE SECTION (4' DIA.) AND SLAB TO BE CAST MONOLITHICALLY.

REVISED:
SEPT-2009

GRAVITY SEWER SYSTEM - DROP MANHOLE

STANDARD
DETAIL

ISSUED:
SEPT - 2009

CITY OF WEST PALM BEACH ENGINEERING SERVICES DEPT.

GS-4