



1. SEE "VALVE BOX SETTING" STANDARD (P-1) FOR ADDITIONAL DETAILS.
2. ALL BUTTERFLY VALVES SHALL BE INSTALLED WITH AN IN-LINE SLEEVE.
3. ALL JOINTS SHALL BE RESTRAINED.

REVISED: SEPT-2009	<b>PRESSURE PIPE - BUTTERFLY VALVE SETTING</b>	STANDARD DETAIL
ISSUED: SEPT - 2009	<b>CITY OF WEST PALM BEACH ENGINEERING SERVICES DEPT.</b>	P-2