

## PUMP PANEL: NAME PLATE SCHEDULE

NO.	SIZE	DESCRIPTION
1.	1 x 3"	DUPLEX PUMP PANEL
2.	1 x 3"	MAIN CIRCUIT BREAKER (MCB)
3.	--	--
4,6.	1 x 3"	PUMP NO. 1
5,7.	1 x 3"	PUMP NO. 2
8.	1/2 x 2"	CONTROLS
9.	1/2 x 2"	GFI
10.	1/2 x 2"	RTU
11.	1/2 x 2"	CONTROL POWER
12.	1-1/2 x 3"	CAUTION: TO AVOID RISK OF FIRE, REPLACE ONLY WITH SAME FUSE TYPE & FUSE RATING.
13.	1 x 3"	USE 75°C RATED COPPER WIRE
14.	1 x 3"	BACK-UP CONTROLLER
PL 1,2		ON
PL 3		ALARM LIGHT (HIGH)
PL 4		LOW LEVEL
PL 5		POWER ON
SS 1,2		HAND-OFF-AUTO

REVISED:  
SEPT-2009

**SUBMERSIBLE LIFT STATION - PUMP PANEL:  
NAME PLATE SCHEDULE**

STANDARD  
DETAIL

ISSUED:  
SEPT - 2009

**CITY OF WEST PALM BEACH ENGINEERING SERVICES DEPT.**

SLS-11