



"The Capital City of the Palm Beaches"

PROCUREMENT DIVISION

401 Clematis St. 5th Floor
West Palm Beach, FL 33401
TEL: (561) 822-2100
FAX: (561) 822-1564

**Addendum No. 1
ITB 09/10-24**

Bulk Hypochlorite Storage and Feed System (Rebid)

Each recipient of this Addendum No. 1 to the Invitation to Bid (hereinafter "ITB") who responds to the ITB acknowledges all of the provisions set forth in the ITB and agrees to be bound by the terms thereof. This addendum shall modify, clarify, change or add information and clarification and become part of the above referenced ITB.

ADVERTISEMENT PAGE:

Please insert the attached advertisement page with your bid packet.

QUESTION AND ANSWER:

Question 1: Drawing D-03-01 indicates 3'-0" x 7'-6" doors. Are these modular door frame dimensions for standard 3'-0" x 7'-0" doors, or does this usage require special order doors and frames to allow equipment to be installed?

Answer 1: Change: 3'-0" x 7'-6" Double Doors
To: 3'-0" x 7'-0" Double Doors

Question 2: The two 8700 gallon tanks the city is buying are they to be used for temporary bleach system.

Answer 2: Yes, they will be used temporary bulk storage of Bleach.

Proposers must acknowledge receipt of this Addendum No. 1 in the space provided below. This Addendum forms an integral part of the ITB documents and therefore must be executed. Failure to return this addendum with your proposal submittal may be cause for disqualification.

Issued By: City of West Palm Beach
Procurement Division
February 3, 2010

Signed By: 
Nora W. Lauder milk
Procurement Official

PROPOSER:

Signed By: _____
Print Name: _____
Title: _____
Date: _____



"The Capital City of the Palm Beaches"

PROCUREMENT DIVISION
401 Clematis Street, 5th Floor
West Palm Beach, FL 33401
TEL: (561) 822-2100
FAX: (561) 822-1564

INVITATION TO BID # 09/10-24

BULK HYPOCHLORITE STORAGE AND FEED SYSTEM (REBID)

The City of West Palm Beach is accepting bids from qualified and responsible contractors to furnish all labor, materials, tools, equipment and incidentals and perform all Work required to construct complete in place and ready to operate a sodium hypochlorite storage and feed system. The new system will replace an existing chlorine gas disinfection system. Work includes: demolition of the one ton cylinder chlorine gas handling system, chlorine gas piping, chlorinators, and emergency chlorine gas scrubber; providing metering pumps in a new prefabricated building; providing a hypochlorite day tank; providing temporary sodium hypochlorite storage and transfer system; and associated yard piping and all appurtenances.

Bid documents may be acquired electronically and free of charge by logging onto the City's Engineering Department's website at:

http://www.wpb.org/engineering/eng_bids.htm

Hard copies of bid documents may also be acquired from the Engineering Services Department, at **401 CLEMATIS STREET 4TH FLOOR, WEST PALM BEACH, FLORIDA, 33401, and (561) 494-1040**. There will be a non-refundable fee of **\$250.00** for each set of plans and specifications. It is suggested that all interested parties call to inquire as to the current availability of plans and specifications.

Time is of the essence and any bid received after **11:00 a.m. Tuesday, February 16, 2010**, whether by mail or otherwise, will be returned unopened. The time of receipt shall be determined by the time clock located in the office of the Procurement Official. Bids shall be placed in a sealed envelope, marked in the lower left-hand corner with the bid number, title, date, and hour bids are scheduled to be received. Offerors are responsible for insuring that their bid is stamped by Procurement office personnel by the deadline indicated.

All bids must be delivered or mailed to:

City of West Palm Beach Procurement Division
Nora W. Laudermilk, Procurement Official
401 Clematis Street 5th Floor

West Palm Beach, Florida 33401

ENVELOPES CONTAINING BIDS MUST BE IDENTIFIED AS ITB #09/10-24. Bids shall be accompanied by a certified check, cashiers check, or Bid Bond in an amount not less than 5% of bid.

PLEASE NOTE: NO PREBID CONFERENCE IS REQUIRED



Nora W. Laudermilk, FCCN
Procurement Official

PUBLISH: PALM BEACH POST
January 17, 2010