



"The Capital City of the Palm Beaches"

PROCUREMENT DIVISION

PO Box 3366
West Palm Beach, FL 33402
TEL: (561) 822-2100
FAX: (561) 822-1564

**ADDENDUM #2
ITB #10/11-19**

Automatic Water Level Control System for AB-5

Each recipient of this Addendum No. 2 to the Invitation to Bid (ITB) who responds to the ITB acknowledges all of the provisions set forth in the ITB and agrees to be bound by the terms thereof. This addendum shall modify and become part of the above referenced ITB.

I. QUESTION AND ANSWER

Question 1: I don't see any scale or bar on sheet 4 to measure distance for conduit to and from the gate actuators. Please provide. **Answer 1:** Scale on sheet 4 is 1 inch equals 30 feet.

Question 2: Sheet 5, note 15 and the panel schedule indicates the new power distribution pane shall be Nema 3R. Are you sure you want 3R instead of 4X, and do you want 304 or 316 stainless steel?
Answer 2: Sheet 5, note 15 a iii. Type shall be Nema 4X 316SS

Proposers must acknowledge receipt of this Addendum Number Two in the space provided below. This Addendum forms an integral part of the documents and therefore must be executed. Failure to return this addendum with your proposal submittal may be cause for disqualification.

Issued By: City of West Palm Beach
Procurement Division
May 11, 2011

Issued By: _____
Donna Levengood, CPPO, FCCN
Assistant Purchasing Manager

Bidder: _____

Signed By: Donna Levengood
Print Name: _____
Title: _____
Date: _____

End of Addendum #2