

CONDENSATE LINE,
SEE PLAN FOR SIZE
AND LOCATION.
INSTALL CONDENSATE
DRAINS WITH 1/8" PER
FOOT PITCH

GRADE

12

GROUT AT INLET

NEENAH MODEL R-1691-B
CAST IRON MANHOLE
COVER AND FRAME
SIZED FOR PIPE END

18" DIA X 48" REINFORCED
CONCRETE BELL END
DRAIN PIPE

FILL PIPE WITH 3/4" MINIMUM
DIAMETER WASHED RIVER
ROCK

FILL WITH 1/2" CUBIC YARD
OF 3/4" MINIMUM DIAMETER
WASHED RIVER ROCK
WRAPPED IN DELINEATION
NON-WOVEN GEOTEXTILE
BY MIRAFI, OR
APPROVED EQUAL

CONDENSATE DRAIN DRYWELL

REV 062309

H-113

NOTE TO DESIGNER/ENGINEER

THE STANDARD DETAILS AND
AND PRODUCTIVITY ON MANHOLE
WITHOUT PROFESSIONAL REVISION
STANDARDS THAT CAN BE USED
CUSTOMIZATION INTO THE C