



"The Capital City of the Palm Beaches"

PROCUREMENT DIVISION

401 Clematis Street, 5th Floor
West Palm Beach, FL 33401
TEL: (561) 822-2100
FAX: (561) 822-1564

**Addendum No. 1
ITB 10-11-32**

19th and 21 Streets Improvements

This addendum shall modify, clarify, change or add information and become part of the above referenced Invitation to Bid.

Each recipient of this Addendum No. 1 acknowledges all of the provisions set forth in the Invitation to Bid and agrees to be bound by the terms thereof.

The purpose of this addendum is to provide answers to questions received:

Question 1:

At the bottom on the "Schedule of Bid Items" it states, "Bid Items 28 & 29: Contractor to provide pricing for all items. City of West Palm Beach reserves the right to choose between Bahia sod and Empire turf based on neighborhood request." However, the schedule of bid items does not show bid items 28 & 29 nor does it make provision to price sod as an add alternate. How should we add for the cost of sod and what are the quantities?

Answer 1:

Landscaping was eliminated from this bid due to drought conditions. It may be requested again, but, not prior to awarding. Please do not price the sod.

Question 2:

Also, the technical specifications call for line items 23 thru 27 (tree removal, landscape items & mulch) to be included cost. However, these items are not part of the schedule of bid items. Please indicate how we are to proceed pricing these items.

Answer 2:

Please ignore these items. Again, landscaping was eliminated from this bid due to drought conditions. Do not price these items.

Question 3:

Plans do not show irrigation drawings. Are we to assume there is no irrigation for this project?

Answer 3:

Irrigation will not be installed.

Question 4:

The schedule of bid Items does not include landscape as per the plan, how is this going to be quantified?

Answer 4:

Landscape plans were previously included in the design, but, pulled due to the current drought conditions. Please do not bid on any landscape items. If approved, the landscape will be added back in post-award.

Question 5:

The bid Items reflect both asphaltic paving & microsurfacing, please provide a list of acceptable contractors licensed & approved by the CWPB.

Answer 5:

Please refer to our City website for a list of certified vendors (<http://www.wpb.org/procurement/sbiz/vendors.php>)

Question 6:

Will the materials used be governed by FDOT standards?

Answer 6:

No. This is a City project, funded with non-FDOT grant funding.

Question 7:

The asphaltic concrete is quantified by the ton on the bid documents with no quantification as to thickness of asphalt, as the tons increase with thickness, the trucking & handling cost increase, please clarify.

Answer 7:

The units for S-III asphalt should be SY, not Tons.

All other information remains the same.

Bidders must acknowledge receipt of this Addendum No. 1 in the space provided below. This Addendum forms an integral part of the bid documents and therefore must be executed. Failure to return this addendum with your bid submittal may be cause for disqualification.

Issued By: City of West Palm Beach
Procurement Division
October 11, 2011

Issued By: Althea Pemsel
Althea Pemsel, MA, C.P.M.
Procurement Official

BIDDER:

Signed By: _____

Print Name: _____

Title: _____

Date: _____

End of Addendum No. 1