



WEST PALM BEACH

Purchasing Department

**Addendum 2
ITB 17-18-112
January 19, 2018**

Lift Station 44 Improvements

Each recipient of this Addendum acknowledges all of the provisions set forth in the Invitation to Bid (ITB) and agrees to be bound by the terms thereof.

This addendum shall modify, clarify, change or add information and become part of the above referenced ITB.

This Addendum shall provide the following information:

- Questions and Answers
- Reduced SBE Goal

The following documents are included with this addendum:

- Addendum 2 ITB 17-18-112

Questions and Answers

Question 1: Regarding Bid Alternate 3 please provide the following information:

- **How deep are the pipes?**
The existing pipe inverts are shown in NGVD 1929 on sheet C-13. The manhole rim elevations in NGVD 1929 are estimated to be 16.78 for SSMH7667 and 15.80 for SSMH3444. Therefore, the depth of the sewer pipes to be replaced is approximately 10 to 12 feet.
- **Is the Contractor removing and replacing on the same line and grade?**
Yes
- **What is the existing pipe material?**
On sheet C-13, the pipes are shown as VCP.
- **What are the flows in each of these sections? This information is needed for bypass pumping.**
It is estimated that an average of 59,000 gallons per day with a peak hour of 10,000 gallons per hour flow through those two pipes.
- **What are the manhole sizes?**
The contractors should field investigate the existing manhole sizes.

Question 2: Sheet C-10 LS Section calls for 'All Pipes, Flange Bolts & Nuts to be 316SS'. However the fittings are called to be DIP. Is it the intent to use SS Pipe and DI Fittings above ground? Or can all pipe after the FCA be DIP?

Answer

The riser pipes and all pipe above ground shall be stainless steel. The fittings shall be ductile iron.


SBE Goal Reduction

- **The SBE goal is reduced to 10% and SBE material suppliers will count towards the SBE goal percentage.**

All of the other information remains the same.

Proposers must acknowledge receipt of this Addendum 2 in the space provided below. This Addendum forms an integral part of the ITB documents and therefore must be executed. Failure to return this addendum with your proposal submittal may be cause for disqualification.

Issued By: City of West Palm Beach
Procurement Division
January 19, 2018

Signed By: 
Patricia D. Armstrong
Sr. Purchasing Agent

PROPOSER: _____

Signed By: _____

Print Name: _____

Title: _____

Date: _____

End of Addendum 2